



PRODUCT PERFORMANCE REPORT

Document ID 1544282478

Issued on December 8th, 2018

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Eurovent**
 Project reference **BLANDIN**
 Project location **Martinique**

PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.069**
 Brand **MITSUBISHI ELECTRIC**
 Range **M series**
 Product type **Climatiseurs / up to 12 kW / Air cooled / Split / Reverse cycle**
 Product reference **MUZ-AP25VG/MSZ-AP25VG**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	59	dB(A)
Lw1 env	57	dB(A)
Bivalent Point		
Tbiv	-10	Å,Å°C
COP @ Tbiv	2.8	
Ph TBiv	2.4	kW
General		
Mounting	Wall mounted	
MPS	230-1-50	
Refrigerant	R32	
Refr. Line	5m	m
Heating 14511		
Ph @+7	3.2	kW
COP @+7	4.1	
Heating Average Climate		
Pdesignh	2.4	kW
SCOP	4.8	
SCOP Class	A++	
Qhe	698	kWh/annum
Heating Warmer Climate		
SCOP w	5.8	
Qhe w	310	kWh/annum
Poffc		



PRODUCT PERFORMANCE REPORT

Document ID 1544282478

Issued on December 8th, 2018

FEATURE	VALUE	UNIT
Poff	1	W
Psbc		
Psb	1	W
Ptoc		
Pto	8	W
Seasonal Efficiency in Cooling		
Pdesignc	2.5	kW
SEER	8.6	
SEER Class	A+++	
Qce	101	kWh/annum
Thermal		
EER @+35	4.17	
TOL Runing Test		
TOL	-15	Å, Å°C
COP @ TOL	2.6	
Ph @ TOL	2.4	kW